

## WEST BENGAL MEDICAL SERVICES CORPORATION LTD. (Wholly owned by the Government of West Bengal) Swasthya Sathi, GN-29, Sector-V, Salt Lake, Kolkata-700 091.

## **CORRIGENDUM -I**

## TO BIDDING DOCUMENTS FOR

Emergent work for repair & renovation work at the Substation of the factory of Gluconate Health Limited, Dum Dum Canttonment, Kolkata - 700028 (Civil & Electrical works)

Bid Ref. No: WBMSCL/ NIT- 685/2024, Dated- 20/11/2024

Tender ID: 2024\_WBMSC\_771645\_1

| Sl. No. | Section   | Clause/ Sl. No.                         | <b>Current Clause / Provision</b>   | <b>Changed Clause / Provision</b>  |
|---------|---|---|---|--|
| 01      | Annexure-A<br>Electrical<br>Works   | 11.C                                    | INCOMER BUS-COUPLER (1600A<br>ACB)- 1 no.   | BUS-COUPLER (1600A ACB)- 1 no.   |
| 02      | Annexure-A<br>Electrical<br>Works   | 11.D MISC.                              | 1600A, 4P, 50KA,<br>MICROPROCESSOR BASED, EDO<br>TYPE ACB O/L, S/C & E/F<br>PROTECTION WITH 220V AC S/T<br>COIL,MICROSWITCH FOR<br>COMMON FAULT<br>INDICATION,TEST/SERVICE<br>MICRO SW. + DOOR INTERLOCK -<br>3<br>Nos.(KAYCEE/L&T/Siemens/ABB) | Deleted  |
| 03      | INSTRUCTION<br>TO BIDDERS<br>SECTION – A<br>General<br>guidance for e-<br>Tendering | <u>General Terms</u><br>and Conditions: |   | Added Clause: 8. The bidder should have to<br>arrange a total factory/shop testing and<br>inspection of HT Switchgear, Transformer,<br>DG set, LT panels in presence of WBMSCL<br>without any additional cost. |

(Maran 2/12/24 EE (Electrical), WBMSCL