



WEST BENGAL MEDICAL SERVICES CORPORATION LTD.

(Wholly owned by the Government of West Bengal)

Swasthya Sathi, GN-29, Sector-V, Salt Lake, Kolkata-700 091



033-4034 0300,



033-4034 0400

Email ID – info@wbmsc.gov.in

CORRIGENDUM – III

TO

BIDDING DOCUMENTS

FOR

Establishment of 24 bedded hybrid Critical Care Unit at 09(nine) different Government Super Speciality Hospitals- HVAC Work.

Bid Reference No.: WBMSCL/NIT-346/2022, Date: 03/08/2022

Tender ID No: 2022_WBMSCL_393273_2, 2022_WBMSCL_393273_4, 2022_WBMSCL_393273_5, 2022_WBMSCL_393273_6, 2022_WBMSCL_393273_7, 2022_WBMSCL_393273_8

Sl. No.	Page No.	Section	BOQ Sl. No.	Current Clause / Provision	Changed Clause / Provision
1	-	Item Rate BOQ- Price Schedule- Item description	5.00	CABINET TYPE CENTRIFUGAL FAN FOR EXHAUST SYSTEM FOR CRITICAL AREA: Supplying, installing, testing and commissioning (including the charges for lifting, shifting, scaffolding & all other charges or accessories etc.) of factory built Floor Mounted double skin type Exhaust Units made of 25±2mm thick panels with plenum box made of thickness 0.6 mm GI outside and inside layer with polyurethane foam (PUF) insulation of density 40±2 kg/m ³ factory injected between them by injection moulding machine, complete with blower section with blower DIDW forward/backward curved centrifugal fan of static pressure mentioned below, Thermal Break profile, belt drive package with TEFC type VFD drive motor suitable for 415 ± 10% volts, 50 Hz, 3 phase and canvass connection , necessary vibration isolation arrangement, complete as per specifications with suitable rating starter in IP--55 MS enclosure complete with suitable rating TP isolator in IP--55 MS enclosure near the units of following capacities: 3200 cfm, FM Type 85 mmwc SP (2W + 2S) (Make- Elta/Edgetech/VTS/Kruger/Marathon/Green Heck).	CABINET TYPE CENTRIFUGAL FAN FOR EXHAUST SYSTEM FOR CRITICAL AREA: Supplying, installing, testing and commissioning (including the charges for lifting, shifting, scaffolding & all other charges or accessories etc.) of factory built Floor Mounted double skin type Exhaust Units made of 25±2mm thick panels with plenum box made of thickness 0.6 mm GI outside and inside layer with polyurethane foam (PUF) insulation of density 40±2 kg/m ³ factory injected between them by injection moulding machine, complete with blower section with blower DIDW forward/backward curved centrifugal fan of static pressure mentioned below, Thermal Break profile, belt drive package with TEFC type VFD drive motor suitable for 415 ± 10% volts, 50 Hz, 3 phase and canvass connection , necessary vibration isolation arrangement, complete as per specifications with suitable rating starter in IP--55 MS enclosure complete with suitable rating TP isolator in IP--55 MS enclosure near the units of following capacities: 3200 cfm, FM Type 85 mmwc SP (2W + 2S) (Make- Elta/Edgetech/VTS/Kruger/Marathon/Green Heck/ FanAir).
2	-	Item Rate BOQ- Price Schedule- Item description	6.00	AIR CIRCULATION SYSTEM: Supplying, installing, testing and commissioning (including the charges for lifting, shifting, scaffolding & all other charges or accessories etc.) of factory built vertical Floor Mounted double skin TFA type air handling units made of 43±2mm thick panels made of thickness 0.6 mm GI outside and inside layer with polyurethane foam	AIR CIRCULATION SYSTEM: Supplying, installing, testing and commissioning (including the charges for lifting, shifting, scaffolding & all other charges or accessories etc.) of factory built vertical Floor Mounted double skin TFA type air handling units made of 43±2mm thick panels made of thickness 0.6 mm GI outside and inside layer with

Sl. No.	Page No.	Section	BOQ Sl. No.	Current Clause / Provision	Changed Clause / Provision
				<p>(PUF) insulation of density 40 ± 2 kg/m³ factory injected between them by injection moulding machine, complete with blower section with blower DIDW type forward/backward curved centrifugal fan of static pressure as per requirement, 6/8 row deep 4 stage cooling coil section with aluminium finned copper tubes (tube thickness not less than 0.5mm) , Thermal Break profile, belt drive package with TEFC type VFD drive motor suitable for $415 \pm 10\%$ volts, 50 Hz, 3 phase, A.C supply ,drain connections with drain valve, stainless steel drain pan, mixing box, thermometers and pressure gauge at the inlet and outlet of cooling coil and canvass connection , necessary vibration isolation arrangement. Price Should be consist with SITC of 1 nos. 11 TR DX Condensing unit with refrigerant R-407C/R-410A including scaffolding, lifting-shifting, structure etc.</p> <p>2500 cfm, FM Type 65 mmwc SP (1W + 1S) (Make- Zeco/Edgetech/Hitachi/Mitsubishi/O-General /Carrier/Voltas/LG/Daikin).</p>	<p>polyurethane foam (PUF) insulation of density 40 ± 2 kg/m³ factory injected between them by injection moulding machine, complete with blower section with blower DIDW type forward/backward curved centrifugal fan of static pressure as per requirement, 6/8 row deep 4 stage cooling coil section with aluminium finned copper tubes (tube thickness not less than 0.5mm) , Thermal Break profile, belt drive package with TEFC type VFD drive motor suitable for $415 \pm 10\%$ volts, 50 Hz, 3 phase, A.C supply ,drain connections with drain valve, stainless steel drain pan, mixing box, thermometers and pressure gauge at the inlet and outlet of cooling coil and canvass connection , necessary vibration isolation arrangement. Price Should be consist with SITC of 1 nos. 11 TR DX Condensing unit with refrigerant R-407C/R-410A including scaffolding, lifting-shifting, structure etc.</p> <p>2500 cfm, FM Type 65 mmwc SP (1W + 1S) (Make- Zeco/Edgetech/Hitachi/Mitsubishi/O-General /Carrier/Voltas/LG/Daikin/FanAir).</p>

Sd/-

General Manager, WBMSCL &
Deputy Secretary to the Govt. of W.B.